

Cabinets & Counter Models

FD2-10 Controller with LCD5S Display

English



A Division of ITW Ltd Foster Refrigerator Oldmedow Road King's Lynn Norfolk, PE30 4JU United Kingdom

March 2014 Issue 1

Call: +44 (0)843 216 8800

Fax: +44 (0)843 216 4700 www.fosterrefrigerator.co.uk

Email: support@foster-uk.com



Contents

Manual Information & Health & Safety Notes	1
Environmental Management Policy	2
Disposal Requirements & Electrical Safety	2
Start up, Display Icons & Switches	3
Start Sequence, Standby, Access to the Information Menu, Set Point, Keypad Security, Light Settings	4
Defrost, FD2-10 Controller Technical Data & Configuration of Parameters	5
Controller Default & Individual Parameters Explained	6 to 11
Cabinet & Counter Technical Data	12
Wiring Diagrams	13 to 19
Troubleshooting & Notes	20 to 23

Service Manual Information:

The products and all information in this manual are subject to change without prior notice. We assume by the information given that the person(s) working on these refrigeration units are fully trained and skilled in all aspects of their workings. Also that they will use the appropriate safety equipment and take or meet precautions where required.

The service manual does not cover information on every variation of this unit; neither does it cover the installation or every possible operating or maintenance instruction for the units.

Health & Safety Warnings and Information



Make sure the power supply is turned off before making any electrical repairs.



To minimise shock and fire hazards, please do not plug or unplug the unit with wet hands.



During maintenance and cleaning, please unplug the unit where required.



Care must be taken when handling or working on the unit as sharp edges may cause personal injury, we recommend the wearing of suitable PPE.



Ensure the correct moving and lifting procedures are used when relocating a unit.



Do NOT use abrasive cleaning products, only those that are recommended. Never scour any parts of the refrigerator. Scouring pads or chemicals may cause damage by scratching or dulling polished surface finishes.



Failure to keep the condenser clean may cause premature failure of the motor/compressor which will NOT be covered under warranty policy.



Do NOT touch the cold surfaces in the freezer compartment. Particularly when hands are damp or wet, skin may adhere to these extremely cold surfaces and cause frostbite.





Please ensure the appropriate use of safety aids or Personnel Protective Equipment (PPE) are used for you own safety.

Environmental Management Policy



Product Support and Installation Contractors.

Foster Refrigerator recognises that its activities, products and services can have an adverse impact upon the environment.

The organisation is committed to implementing systems and controls to manage, reduce and eliminate its adverse environmental impacts wherever possible, and has formulated an Environmental Policy outlining our core aims. A copy of the Environmental Policy is available to all contractors and suppliers upon request.

The organisation is committed to working with suppliers and contractors where their activities have the potential to impact upon the environment. To achieve the aims stated in the Environmental Policy we require that all suppliers and contractors operate in compliance with the law and are committed to best practice in environmental management.

Product Support and Installation contractors are required to:

- 1. Ensure that wherever possible waste is removed from the client's site, where arrangements are in place all waste should be returned to Foster Refrigerator's premises. In certain circumstances waste may be disposed of on the client's site; if permission is given, if the client has arrangements in place for the type of waste.
- 2. If arranging for the disposal of your waste, handle, store and dispose of it in such a way as to prevent its escape into the environment, harm to human health, and to ensure the compliance with the environmental law. Guidance is available from the Environment Agency on how to comply with the waste management 'duty of care'.
- 3. The following waste must be stored of separately from other wastes, as they are hazardous to the environment: refrigerants, polyurethane foam, and oils.
- 4. When arranging for disposal of waste, ensure a waste transfer note or consignment note is completed as appropriate. Ensure that all waste is correctly described on the waste note and include the appropriate six-digit code from the European Waste Catalogue. Your waste contractor or Foster can provide further information if necessary.
- 5. Ensure that all waste is removed by a registered waste carrier, a carrier in possession of a waste management licence, or a carrier holding an appropriate exemption. Ensure the person receiving the waste at its ultimate destination is in receipt of a waste management licence or valid exemption.
- 6. Handle and store refrigerants in such a way as to prevent their emission to atmosphere, and ensure they are disposed of safely and in accordance with environmental law.
- 7. Make arrangements to ensure all staff who handle refrigerants do so at a level of competence consistent with the City Guilds 2079 Handling Refrigerants qualification or equivalent qualification.
- 8. Ensure all liquid substances are securely stored to prevent leaks and spill, and are **not** disposed of into storm drains, foul drain, or surface water to soil.

Disposal Requirements

If not disposed of properly all refrigerators have components that can be harmful to the environment. All old refrigerators must be disposed of by appropriately registered and licensed waste contractors, and in accordance with national laws and regulations.

General Electrical Safety

Foster Refrigerator recommends that the equipment is electrically connected via a Residual Current Device; such as a Residual Current Circuit Breaker (RCCB) type socket, or through a Residual Current Circuit Breaker with Overload Protection (RCBO) supplied circuit.



Start-Up and Operation

After unpacking, clean and allow the cabinet to stand for 2 hours <u>before</u> turning on. For units that have been delivered outside the UK, please remove the compressor strap as instructed on the front of the unit, before connecting the unit to the mains supply.

Ensure the cabinet is situated away from both hot and cold air sources, as this will affect its performance. Make sure that a minimum clearance of 150mm above the cabinet is available for ventilation and effective operation. Connect the unit to a suitable mains power outlet and turn the supply on. Do not plug or unplug the unit with wet hands.

After connecting the unit to the mains the display will briefly show a dash in the centre of the screen. This will then show $\Box FF$

LCD5S Display Icons and Buttons



Indicators and Buttons

Symbol	Reason	Button	Use
	Alarm	i set	Info / Set Point Button
*	Thermostat Output	₩ 4	Manual Defrost / Decrease Button
*	Fan Output	→ II°	Increase Button / Manual Activation
對	Defrost Output	Ú	Stand-by Button
ll°	Activation of 2 nd parameter set		

Display & Information Icons

During normal operation, the display shows either the temperature measured or one of the following indications:

Symbol	Reason	Symbol	Reason
dEF	Defrost in progress	h.F	Condenser high pressure alarm
oFF	Controller in stand-by	1-11	Room high temperature alarm
<u> </u>	Condenser clean warning	Lo	Room low temperature alarm
do	Door open alarm	EI	Probe T1 failure
he.	Condenser high temperature alarm	<u> </u>	Probe T2 failure
<u> </u>	Instant probe 1 temperature	LLo	Minimum probe 1 temperature recorded
<u> </u>	Instant probe 2 temperature*	<u>rnd</u>	Compressor working weeks**
<u> </u>	Instant probe 3 temperature*	Loc	Keypad state lock
<u> </u>	Maximum probe 1 temperature recorded		

^{*} Displayed only if enabled (see configuration parameters)

** Displayed only if ACC > 0

Start Sequence



For normal operation

Press and hold the $\mathbf{0}$ button for 3 seconds then release. The current cabinet temperature will be displayed.

If pressed and held for 5 seconds then released this will start the 'Test Sequence' $\not = \not \subseteq \not = \bot$.

The test function is a defined sequence of events that will follow a prescribed pattern (dependent upon parameter values) that will operate all electrical elements of the system, simulating a short operating pattern. It should enable an engineer to carryout basic function operations checks of all system parts including refrigeration.

This sequence can take, and the display will count up to, a maximum of 935 seconds before showing '上っぱ'. The length of time the test is run will be dependent on the model type and conditions the unit is placed in. After showing 'End' the controller will wait for 1 min, then resume normal operation and show the current temperature of the unit.

To cancel the test sequence prior to completion, press and release **U**.

Standby

When pressing the 0 button for 3 seconds, the unit will enter the standby mode and display $\Box FF$ (unless already in standby and then this will energise the controller to show the current unit temperature).

This ${}^{\prime}\Box FF'$ indication will be displayed while the unit is not operating but the mains power is applied to the unit. This mode may be used for interval cleaning regimes and short periods when the unit is not required. For extended periods of inactivity the mains supply should be isolated.

Access the menu and information

- Press and immediately release the **1** button.
- Using the and or buttons select the data you wish to display
- Press the **İ** button to display the current value.
- To exit press the **U** button or wait 10 seconds.

To reset the THI and TLO:

- Display the value with the **1** button
- While keeping the **i** button pressed, press the **b** button to reset.

Set Point and Display Modification

- Press button i and hold for half a second.
- By keeping button i pressed, use \vee and or \wedge buttons to set the desired value (adjustment is within the minimum SPL and the maximum SPH limit)
- When button **İ** is released, the new value is stored.

Keypad Security Settings

The keypad lock avoids undesired, potentially dangerous operations, which might be attempted when the controller is operating in a public place. In the INFO menu, set parameter $\angle \Box c = YES$ to inhibit all functions of the button. To resume normal operation of keypad, adjust setting so that $\angle \Box \Box = NO$.

Internal Light Operation for Glass Door Models

Where fitted the light can be turned on or off by pressing and releasing the button.



Defrost



Automatic Defrost

Defrost starts automatically as soon as the time set with parameter DFT has elapsed.

- **Time Defrost** With DFM = TIM defrost takes place at regular intervals when the timer reaches the value DFT. For example, with DFM = TIM and DFT = 06, a defrost will take place every 6 hours.
- **Defrost time count backup** At power restoration, if DFB = YES, the defrost timer resumes the time count from where it was prior to the power interruption. If DFB=NO, the time count re-starts from 0. In stand-by the accumulated time count is frozen.

Defrost Type – When defrost has started, compressor and defrost outputs are controlled according to the parameter DTY. If FID = YES, the evaporator fans are active during defrost.

Resuming Thermostatic Cycle

When defrost is complete, if DRN is greater than 0, all outputs will remain off for the DRN minutes.

Manual Defrost



To initiate a manual defrost press and hold the defrost button for 2 seconds.

FD2-10 Technical Data

Power Supply

230Vac±10%, 50/60Hz, 3W

Relay Output Max Load (230Vac) Compressor – 16(8) A 240Vac

Defrost - 16(4) A 240Vac Evap. Fan - 16(4) A 240Vac Auxiliary Loads 1 - 8(2) A 240Vac

Input – NTC 10KΩ @ 25°C

Measurement Range

-50...120°C, -55...240°F -50 / -9.9...19.9 / 80°C (NTC 10K Only)

Measurement Accuracy

<0.5°C within the measurement range

Operating Conditions

-10 ... +50°C; 15% ... 80% r.H

Controller Approvals

EN60730-1; EN60730-2-9 EN55022 (Class B) EN50082-1

Configuration of Parameters

Parameters should not be changed unless you have an understanding of their purpose and the following instructions are fully understood.

- To gain access to the parameters access the configuration menu by pressing $\mathbf{0} + \mathbf{i}$ together for 5 seconds.
- The first parameter will show on the display.
- Using the and or buttons select the required parameter.
- Press the i button to display its current value.
- While keeping i pressed, use the and or buttons to set the new desired value.
- On releasing **i** the new value will be stored and the next parameter will display.
- To exit this mode or revert to normal operating mode, press 0 or wait for 30 seconds.

If at any point no buttons are pressed for 30 seconds, without saving a new value, the display will return to the standard temperature display.

FD2-10 Controller Default Parameter Values & Descriptions



Parameter	Range	Description	Foster FD2-10
		Readout Scale:	
SCL	1°C	Range -50/-9.9 19.9/80°C (With INP = SN4 Only)	2°C
SCL	2°C	Range -50 120°C	2 0
	°F	Range -55 240°F	
SPL	-50 SPH	Minimum Limit for SP setting	1
CDLI	SPL120°	Maying up limit for CD acting	2
SPH	SPL 120	Maximum limit for SP setting	3
SP	SPL SPH	Temperature set point to be achieved	2
	0		_
		Temperature Control mode:	
C-H	REF	Refrigeration	REF
	HEA	Heating	
HYS	1 10°	Off/On Thermostat differential	3
CRT	0 30min	Compressor Rest Time	2
CIXI	0 3011111	Compressor ivest fillie	2
074	0.00	Thermostat run time with faulty T1	0
CT1	0 30min	(CT1 = 0 output with faulty T1 will always be off)	6
CT2	0 30min	Thermostat off time with faulty T1 probe.	4
012	0 00111111	(CT2=0 & CT1 = >0 output with faulty T1 will always be on	7
		Compressor stan delay ofter dear has been appead	
CSD	0 30min	Compressor stop delay after door has been opened (Only if DS – YES)	1
		(Only ii b3 = 1E3)	
		Defrost Start Mode:	
5-14	Non	Defrost function is disabled	
DFM	TIM	Regular time defrost	— TIM
	FRO	Defrost time elapses only in condition of frost accumulation	
		· · ·	
DFT	099 Hours	Time interval between defrosts	6
555	\/F0	Defrost timer clock	\/50
DFB	YES	Following mains interruption, timer resumes count	YES
	NO	Following mains interruption, timer restarts from zero	
		Defrost end temperature	
DLI	-50 120°	(Only if T2 = EPO)	N/A
DTO	1 120min	Maximum defrost duration	20
		Defrost Type:	
DTY	OFF	Timed off cycle defrost (compressor and heater off)	OFF OFF
	ELE	Electric heater defrost (compressor off, heater on)	
	GAS	Hot gas defrost (compressor and heater on)	
DPD	0 240 sec	Evaporator pump down. Timed pause at start of defrost	0
51.0	J 270 360	Evaporator pump down. Timed pause at start of defrost	U
DRN	0 30min	Drain down period	2
			_
		Defrost display mode:	
	RT	Real (actual) air temperature	
DDM	LT	Last temperature display before start of defrost	DEF
	SP	The current set point value.	
	DEF	"DEF"	



DDY	0 60 min	Defrost display delay period Time DDM is shown following defrost termination	10
FID	YES NO	Fans in defrost: Fans run during defrost Fans do not run during defrost	YES
FDD	-50 120°	Evaporator fan restart temperature following defrost (Only if T2 = EPO)	5
FTO	0120 min	Maximum evaporator fan stop period following defrost	3
FDS	0120 sec	Minimum evaporator fan stops (following door opening etc.)	20
FCM	NON TMP	Evaporator fan mode during thermostatic control: Fan(s) run continuously Temperature based control. When compressor is on, fans are on. When compressor is of, fans run as long as temperature difference	TIM
FOIVI	Tim	Te-Ta > FD. Fans on again with FDH Time based control. When compressor is on, fans are on. When compressor is off, fans in accordance to parameters FT1, FT2 and FT3.	11101
FDT	-120 0°	Te-Ta difference for fans to turn off after compressor stopped. (Only if T2 = EPO and FCM = TMP)	-1
FDH	1 120°	Temperature differential for evaporator fan restart. (Only if T2 = EPO and FCM = TMP)	3
FT1	0 180 Sec	Fan stop delay after compressor stop.	15
FT2	0 30min	Timed fan stop following T1 (With FT2 = 0 the fans remain on all the time).	3
FT3	0 30min	Timed fan run following FT2 (With FT3 = 0 and FT2 > 0 the fans remain off all the time.	2
АТМ	NON ABS REL	Alarm threshold configuration: All temperature alarms are inhibited The value set in ALA and AHA represent actual alarm set points The values set in ALR and AHR are alarm differentials which relate to SP and SP + HYS	REL
ALA	-50 120°	Low temperature alarm threshold	
AHA	-50 120°	High temperature alarm threshold	
ALR	-12 0°	Low temperature alarm differential (With ALR = 0 the low temperature alarm is excluded)	-5
AHR	0 12°	High temperature alarm differential (With AHR = 0 the low temperature alarm is excluded)	5
ATI	T1 T2	Alarm probe: Air temperature probe used for alarm detection Evaporator temperature probe used for alarm detection	T1
ATD	0 120min	Delay before alarm temperature warning	90



ADO	0 30min	Delay before door open alarm warning	8
		Operation in case of high condenser alarm (T2 = CND)	
	NON	High condenser temperature alarm inhibited	
AHM	ALR	Condenser warning – 'HC' displayed, alarm sounds	NON
	STP	As 'ALR' with compressor stopped and defrosts suspended	
AHT	-50 120°	Condenser alarm temperature (T2 = CND)	65
ACC	052 Weeks	Condenser cleaning period.	0
		(With ACC = 0 condenser cleaning is disabled)	
		Switchover method to second parameter set:	
	NON	Second parameter set is excluded	
IISM	MAN		HDD
IIOIVI		Second parameter set is activated/ deactivated by button	טטוז
	HDD D13	Second parameter activated by 'heavy' usage	
	D12	Second parameter set activated by D12 input (D12 = IISM)	
IISL	-50 . IISH	Minimum limit for IISP setting	1
IIOL	00.11011	William in the for field setting	1
IISH	IISL 120°	Maximum limit for IISP setting	1
		ŭ .	
IISP	IISPIISH	Temperature set point to be achieved in 'Mode 2'	1
IIHY	1 10°	Off/on thermostat differential in 'Mode 2'	3
		Even outton for mode division (Mode 2) the mode to control.	
	NON	Evaporator fan mode during 'Mode 2' thermostatic control: Fans(s) run continuously	
	NON	Temperature based control. When compressor is on, fans are on.	
	TMP	When compressor is off, fans run as long as temperature difference	
IIFC	LIVIE	Te-Ta>FDT. Fans on again with FDH	NON
		Time based control. When compressor is on, fans are on. When	
	TIM	compressor is off, fans in accordance to parameters FT1, FT2 and	
	1	FT3.	
HDS	1 5	Controller sensitivity for switch over between 'Modes' and 2.	3
1100	1 9	(1 = minimum, 5 = maximum)	3
UDE	0.00 ======	Times internal hatures defeats in (Made O)	•
IIDF	0 99hours	Time interval between defrosts in 'Mode 2'.	6
		Standby button operation:	
SB	YES	Standby button enabled	YES
02	No	Standby button disabled	. 20
		Door switch operation (switch made when door closed):	
DS	YES	Door switch enabled	YES
	NO	Door switch disabled	
	14014	Configuration digital input operation:	
	NON	Digital input 2 not activated	
DI2	HPS	High pressure alarm when contact opens	NON
	RDS	'Mode 2' parameters active when contact closes Defrost initiated when contact closes	
		TO THE CONTROL OF THE	
	DS2	Second door switch function (operated 'in series' with DS)	



	NON	Light control mode: Digital input 2 not activated	
. 014	MAN	Light output operation is activated/deactivated by button (With OA1 = LGT)	NON
LSM	DOR	Light output is switched on when door is opened (With OA1 = LGT and DS = YES)	NON
	NDR	Light output is switched off when door is opened. (With OA1 = LGT and DS = YES)	
		,	
		Auxiliary relay operation:	
	NON	Output disabled (always off)	
	0-1	Contacts open/close with standby/on mode	
OA1	LGT	Output enabled for light control	NON
	AL0	Contacts open when an alarm condition occurs	
	AL1	Contacts close when an alarm condition occurs	
		(Relay contacts open when in standby mode)	
		Temperature sensor(s) type:	
INP	SN4	10k NTC type thermistor (red writing)	SN4
	ST1	1k PTC type thermistor (Black Writing)	
OS1	-	Air temperature probe (T1) offset.	0
	12.512.5°C		Ů
		TO D. I. C. (1)	
	NON	T2 Probe function:	
T2	NON	T2 Probe disabled	NON
	EPO	Evaporator temperature monitoring	
	CND	Condenser temperature monitoring	
		TO much a term another offset	
OS2	- 12.512.5°C	T2 probe temperature offset	0
	12.512.5 C		
TLD	1 30min	Delay for min (TLO) and max. (THI) temperature logging	10
ILD	1 30111111	belay for milit (120) and max. (111) temperature logging	10
SIM	0 100	Display Slowdown	5
ADR	1 255	FD2-10 address for PC communication	1

Xtra Cabinets and Counter Parameter Values



		FD2-10 Default	XR600H	XR1300H	XR600L	XR1300L	XR2H & XR3H
ī	Danamatan		AT	AW	AZ	BB	BD
	Parameter SCL	2°C	2°C	2°C	2°C	2°C	2°C
	SPL	1	1	1	-21	-21	1
	SPH	3	3	3	-15	-15	3
	SP	1	1	1	-21	-21	1
	C-H	REF	REF	REF	REF	REF	REF
	HYS	4	3	3	3	3	3
	CRT	2	2	2	2	2	2
	CT1	6	6	6	6	6	6
	CT2	4	4	4	4	4	4
	CSD	1	1	1	1	1	1
	DFM	TIM	TIM	TIM	TIM	TIM	TIM
	DFT	6	6	6	6	6	6
	DFB	YES	YES	YES	YES	YES	YES
	DLI	20	20	20	20	20	20
	DTO	20	20	20	20	20	20
	DTY	OFF	OFF	OFF	ELE	ELE	OFF
	DPD	0	0	0	0	0	0
	DRN	2	2	2	2	2	2
	DDM	DEF	DEF	DEF	DEF	DEF	DEF
	DDY	10	10	10	10	10	10
	FID	YES	YES	YES	NO	NO	YES
	FDD	5	5	5	5	5	5
	FTO	3	3	3	3	3	3
	FDS	20	20	20	20	20	20
	FCM	TIM	NON	NON	NON	NON	NON
	FDT	-1	-1	-1	-1	-1	-1
	FDH	3	3	3	3	3	3
	FT1	15	15	15	15	15	15
	FT2	3	3	3	3	3	3
	FT3	2	2	2	2	2	2
	ATM	REL	REL	REL	REL	REL	REL
Only visible with	ALA	-2	-2	-2	-2	-2	-2
ATM = ABS	AHA	8	8	8	8	8	8
Only visible with	ALR	-5	-5	-5	-5	-5	-5
ATM = REL	AHR	5	5	5	5	5	5



			AT	AW	AZ	ВВ	BD
	ATI	T1	T1	T1	T1	T1	T1
	ATD	90	90	90	90	90	90
	ADO	8	8	8	8	8	8
	АНМ	NON	NON	NON	NON	NON	NON
	AHT	65	65	65	65	65	65
	ACC	0	0	0	0	0	0
	IISM	HDD	NON	NON	NON	NON	NON
	IISL	1	1	1	1	1	1
	IISH	1	1	1	1	1	1
Only visible	IISP	1	1	1	1	1	1
when IISM is changed from NON	IIHY	4	4	4	4	4	4
	IIFC	NON	NON	NON	NON	NON	NON
	HDS	3	3	3	3	3	3
	IIDF	6	6	6	6	6	6
	SB	YES	YES	YES	YES	YES	YES
	DS	YES	YES	YES	YES	YES	NO
	DI2	NON	NON	DS2	NON	DS2	NON
	LSM	NON	NON	NON	NON	NON	NON
	OA1	0-1	NON	NON	NON	NON	NON
	INP	SN4	SN4	SN4	SN4	SN4	SN4
	OS1	0	0	0	0	0	0
	T2	NON	NON	NON	EVP	EVP	NON
Shows only if T2 is enabled	OS2	0	0	0	0	0	0
	TLD	10	10	10	10	10	10
	SIM	5	5	5	5	5	5
	ADR	1	1	1	1	1	1

Yellow highlighted parameters show a difference from the default set parameter.



Technical Data of Individual Models


GB

Cabinet	5.5	1,11	Cac Charge	Comprocess) aclino	Defrost	Power Co	Power Consumption	Fuse
Models	Cas S	71 IAU	das Cilaige	Compressor	Capillary	Type	Watts	Amps	Rating
VBEOOL	R134a	2H0S	150 grams	EMT6160Z	0.042" ID x 2.7m	Off Cycle	510	2.6	13
בוחחסאע	R134a	PH09	150 grams	NEK6160Z	0.042" ID x 2.7m	Off Cycle	510	2.6	13
VDEOOL	R404	2H0S	280 grams	NEK2168Z	0.042" ID x 2.7m	Hot Gas	610	3.2	13
AROUGE	R404	ZH09	280 grams	NEK2168GK	0.042" ID x 2.7m	Hot Gas	610	3.2	13
VB4200U	R134a	2H0S	420 grams	NEK6212Z	0.042" ID x 2.8m	Off Cycle	780	3.7	13
בחחפואל	R134a	ZH09	420 grams	NEK62102	0.042" ID x 2.8m	Off Cycle	780	3.7	13
VD4200I	R404	20Hz	435 grams	NT2180GK	0.054" ID x 2.6m	Hot Gas	970	5.1	13
AN I SOUL	R404	e0Hz	435 grams	NT2192GK	0.042" ID x 2.8m	Hot Gas	970	5.1	13


Counter	7	1			, aciliaco	Defrost	Power Col	Power Consumption	Fuse
Models	G S	71 IAU	das Cilaige	Compressor	Capillaly	Type	Watts	Amps	Rating
VBOL	R134a	zH09	240 grams	EMT6160Z	0.047" ID x 3.0m	Off Cycle	425	2.1	13
באע	R134a	zH09	240 grams	NEK61602	0.047" ID x 3.0m	Off Cycle	425	2.1	13
VB2U	R134a	20Hz	240 grams	EMT6160Z	0.047" ID x 3.0m	Off Cycle	515	2.6	13
רופאא	R134a	zH09	240 grams	NEK61602	0.047" ID x 3.0m	Off Cycle	425	2.1	13

Note: The Power Consumption values referred to as tested are to the ECA test standard. Actual power consumption will be greatly affected by ambient temperature, loading, usage and cabinet maintenance.











RY FOSTER











RY FOSTER










GB





GB

Troubleshooting



Problem

Possible Cause

Solution

Audible & Visual Alarms/Warnings




- Low temperature alarm
- High temperature alarm
- T1 Air probe failure
- T2 Evaporator probe failure#
- Condenser clean warning#
- Condenser high temperature alarm#
- High pressure alarm#
- Door open alarm#

- Cancel audible alarm and investigate cause.
- > Cancel audible alarm and investigate cause.
- > Check and replace the air probe
- > Check and replace the evaporator probe
- > Carry out cleaning regime on the condenser. The timer is reset when power is removed and reset.
- Clean condenser and ensure ambient temperature is not too high.
- > Check ambient temperature and refrigeration system.
- > Press to silence alarm and close the door. If the alarm persists and the door is closed check and replace the door switches.

Compressor will not start



Electrical conductor or wires may be cut



- Defective electrical component: thermostat, relay, thermal protector etc.
- Compressor motor has a winding open or shorted
- Compressor stuck
- Temperature control contacts are open
- Incorrect wiring
- Fuse blown or circuit breaker tripped.
- Power cord unplugged
- Controller set too high
- > Cabinet in defrost cycle

- Use voltmeter to check
- > Use ohmmeter to check for continuity
- Replace defective component
- Measure ohmic resistance of main and auxiliary winding using ohmmeter. Compare with correct values
- Change compressor
- > Repair or replace the contacts
- Check wiring diagram and correct
- Replace fuse or reset circuit breaker
- Plug in power cord.
- > Set controller to lower temperature.
- > Wait for defrost cycle to finish


^{*} only displayed if applicable to model and enabled through parameters



The temperature is too cold

- Controller is set at a very cold position
- Set to warmer position and check if the compressor stops according to controllers operating range.
- Controller does not disconnect the condensing unit
- > Check the insulation of the thermostat. If problem persists, change the thermostat
- Control contacts are stuck closed
- Change the control. Check amperage load
- Defective or incorrect temperature control
- Determine correct control and replace.

The temperature is not cold enough



Adjust to colder setting



Condenser is dirty

Clean condenser




- The refrigerator has been placed at an inadequate location
- The unit must not be near stoves, walls that are exposed to the sun, or places that lack sufficient air flow.



- Compressor is inefficient or there is a high pressure due to the air in the system
- If there is air in the system, purge and recharge



- Iced up evaporator coil
- > Check temperature control, refrigerant charge, and defrost mechanism. Remove all ice manually and start over.



Locate exact point of restriction and correct



- The refrigerator has been used improperly
- The shelves must never be covered with any type of plastic or other material that will block the circulation of cold air within the refrigerator.



- Too many door openings
- Advise user to decrease if possible



- Excessive heat load placed in cabinet
- Advise user not to put in products that are too hot.



- The refrigerator has been overcharged with the refrigerant gas
- Check to see if condensation or ice crystals have formed on the suction line. If so, charge with the correct amount of gas.



- The refrigerant gas is leaking
- > Find the location of gas leak in order to seal and replace the defective component. Change the drier. Perform a good vacuum and recharge unit.



- The evaporator and/or condenser fans are not working
- Check electrical connections and make sure that the fan blade isn't stuck. Replace the fan motor if it doesn't work.





Blocking air flow

- Re-arrange product to allow for proper air flow. Make sure there is at least four inches of clearance from evaporator.
- Fuse blown or circuit breaker tripped
- Replace fuse or reset circuit breaker.

Electrical Shocks



- Wires or electrical components are in direct contact with metallic parts.
- Check for appropriate insulation on the connections of each component.

Noise



- The refrigerator is not properly levelled
- Check if the noise goes away after you level the refrigerator
- The condenser is not fastened correctly. Copper tubing is in contact with metal
- While the compressor is working, check to see if metal parts are in contact with one another and/or if the screws that fasten the condenser are tightened.
- > The evaporator and/or condenser fans are loose
- Check if the fans are securely fastened. Also, check if the fan blades are loose, broken or crooked. If so, change the faulty blade.
- > Compressor has an internal noise
- If the noise persists after all other measures have been taken, it may be originating from the compressor.

> Loose part(s)

Locate and tighten loose part(s)

Extreme condensation inside the refrigerator

- Controller is set at a very cold position
- Set the controller to a warmer position & check to see if compressor stops as should.
- The outside environment's relative humidity is very high (over 75%)
- This type of occurrence is caused by local climatic conditions and not by the refrigeration unit.
- The refrigerator door won't shut completely
- Check the door and/or the magnetic gasket. Adjust the door hinges if needed; replace the gasket if broken.
- > The refrigerator had been placed at an inadequate location
- The unit must not be near sources that produce too much heat.

Condensing unit runs for long periods of time



- Excessive amount of warm product placed in cabinet
- Advise user to leave adequate time for products to cool down



- Prolonged door opening or door aiar
- Advise user to ensure doors are closed when not in use and to avoid opening doors for long periods of time.





Door gasket(s) not sealing properly



- > Dirty condenser coil
- Evaporator coil iced over
- Ensure gaskets are snapped in completely. Remove gasket and wash with soap and water. Check condition of gasket & replace if necessary
- > Clean condenser coil
- Unplug unit and allow coil to defrost. Make sure thermostat is not set too cold. Ensure that door gasket(s) are sealing properly. Select manual defrost and ensure system works.

-17	JU	ι	е	2



> Page Left Blank Intentionally <





Foster European Operations

France

Foster Refrigerator France SA

Tel: (33) 01 34 30 22 22. Fax: (33) 01 30 37 68 74.

Email: info@foster-fr.com

Germany

Foster Refrigerator Gmbh,

Tel: (49) 781 990 7840. Fax (49) 781 990 7844.

Email: info@foster-gmbh.de

Foster Refrigerator Oldmedow Road Kings Lynn Norfolk PE30 4JU

Tel: 0843 216 8833 Fax: 0843 216 4707

Website: www.fosterrefrigerator.co.uk

Email: support@foster-uk.com

a Division of 'ITW (UK) Ltd'

XTRA CAB & COUNT FD2-10/SM 03/14 V1 GB